



Consumer Confidence Report for Calendar Year 2017

Este informe contiene información muy importante sobre el agua usted bebe.
Tradúscalo ó hable con alguien que lo entienda bien.

Public Water System ID Number	Public Water System Name		
AZ04-09-029	Town of Snowflake		
Contact Name and Title		Phone Number	E-mail Address
Terry Cooper Public Works Director		928-536-7103	tcooper@ci.snowflake.az.us
<p>We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact <u>Snowflake Town Hall</u> at <u>928-536-7103</u> for additional opportunity and meeting dates and times.</p>			

Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source(s):	The Town of Snowflake draws ground water from the Coconino Aquifer through 4 different well sites.
-----------------------------	--

Drinking Water Contaminants

Microbial Contaminants: Such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

Organic Chemical Contaminants: Such as synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

Inorganic Contaminants: Such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

Radioactive Contaminants: That can be naturally occurring or be the result of oil and gas production and mining activities.

Pesticides and Herbicides: Such as agriculture, urban storm water runoff, and residential uses that may come from a variety of sources

Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

Source Water Assessment

The Department of Environmental Quality conducted a Source Water Assessment of this Public Water System In October 2002 and has given a low risk designation for the degree to which this public water system drinking water sources are protected.

Further source water assessment documentation can be obtained by contacting ADEQ, 602-771-4641.

Definitions

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water

Level 1 Assessment: A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present

Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria was present

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health

Maximum Residual Disinfectant Level (MRDL): The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap

Maximum Residual Disinfectant Level Goal (MRDLG): The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur

Minimum Reporting Limit (MRL): The smallest measured concentration of a substance that can be reliably measured by a given analytical method

Millirems per year (MREM): A measure of radiation absorbed by the body

Not Applicable (NA): Sampling was not completed by regulation or was not required

Not Detected (ND or <): Not detectable at reporting limit

Nephelometric Turbidity Units (NTU): A measure of water clarity

Million fibers per liter (MFL)

Picocuries per liter (pCi/L): Measure of the radioactivity in water

ppm: Parts per million or Milligrams per liter (mg/L)

ppb: Parts per billion or Micrograms per liter (µg/L)

ppt: Parts per trillion or Nanograms per liter (ng/L) ppm x 1000 = ppb

ppq: Parts per quadrillion or ppb x 1000 = ppt

Picograms per liter (pg/L) ppt x 1000 = ppq

Lead Informational Statement:

Lead, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children.

Town of Snowflake is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Water Quality Data – Regulated Contaminants

Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MCL	MCLG	Likely Source of Contamination	
E. Coli	N	0	0	0	0	Human and animal fecal waste	
Fecal Indicator (coliphage, enterococci and/or E. coli)	n/a	n/a	n/a	0	0	Human and animal fecal waste	
Surface Water Treatment Rule	TT Violation Y or N	Highest Level Detected	% Range (Low-High)	TT	Sample Month & Year	Likely Source of Contamination	
Total Organic Carbon ¹ (mg/L) <i>if</i>	n/a	n/a	n/a	TT	n/a	Naturally Present in the Environment	
Turbidity ² (NTU)	n/a	n/a	n/a	TT	n/a	Soil runoff	
<p>¹ Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THM) and haloacetic acids (HAA). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver, or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.</p> <p>² Turbidity is a measure of the cloudiness of water and is an indication of the effectiveness of our filtration system. We monitor it because it is a good indicator of the quality of water. High turbidity can hinder the effectiveness of disinfectants. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.</p>							
Disinfectants	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MRDL	MRDLG	Sample Month & Year	Likely Source of Contamination
Chlorine/Chloramine (ppm)	N	0.507	0.455 – 0.635	4	0	6/month 2017	Water additive used to control microbes
Chlorine dioxide (ppb)				800	0		Water additive used to control microbes
Disinfection By-Products	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)	N	2.5	<1 – 2.5	60	N/A	08/2017	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	N	8.5	<2 – 8.5	80	N/A	08/2017	Byproduct of drinking water disinfection
Bromate (ppb)				10	0		Byproduct of drinking water disinfection
Chlorite (ppm)				1	0.8		Byproduct of drinking water disinfection
Lead & Copper	MCL Violation Y or N	90 th Percentile	Number of Samples Exceeds AL	AL	ALG	Sample Month & Year	Likely Source of Contamination
Copper (ppm)	N	0.15	0	1.3	1.3	08/2016	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	1.4	0	15	0	08/2016	Corrosion of household plumbing systems; erosion of natural deposits
Radionuclides	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Beta/Photon Emitters (mrem/yr.)				4	0		Decay of natural and man-made deposits
Alpha Emitters (pCi/L)	N		1.4 – 4.5	15	0	02/2013	Erosion of natural deposits
Combined Radium-226 & -228 (pCi/L)	N		0.6 – 0.9	5	0	02/2013	Erosion of natural deposits
Uranium (ug/L)				30	0		Erosion of natural deposits
Inorganic Chemicals (IOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Antimony (ppb)	N	<1	<1	6	6	02/2013	Discharge from petroleum refineries; fire retardants; ceramics, electronics and solder
Arsenic ¹ (ppb)	N	1.2	<1 – 1.2	10	0	02/2013	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
Asbestos (MFL)	N	<0.2	<0.2	7	7	02/2013	Decay of asbestos cement water mains; Erosion of natural deposits

Barium (ppm)	N	0.054	0.035 -- 0.054	2	2	02/2013	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	N	<1	<1 - <1	4	4	02/2013	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	N	<0.5	<0.5 - <0.5	5	5	02/2013	Corrosion of galvanized pipes; natural deposits; metal refineries; runoff from waste batteries and paints
Chromium (ppb)	N	1.4	<1 - 1.4	100	100	02/2013	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (ppb)	N	<25	<25 - <25	200	200	02/2013	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories
Fluoride (ppm)	N	0.28	0.066 -- 0.28	4	4	02/2013	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (ppb)	N	<0.2	<0.2 - <0.2	2	2	02/2013	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills and cropland.
Nitrate (ppm)	N	0.59	0.10 - 0.59	10	10	05/2017	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite ² (ppm)	N	<0.05	<0.05 - <0.05	1	1	02/2013	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	N	5.1	<5 -- 5.1	50	50	02/2013	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium (ppm)				N/A	N/A		Erosion of natural deposits
Thallium (ppb)	N	<1	<1 - <1	2	0.5	02/2013	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

¹ Arsenic is a mineral known to cause cancer in humans at high concentration and is linked to other health effects, such as skin damage and circulatory problems. If arsenic is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water, and continues to research the health effects of low levels of arsenic.

² Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause "blue baby syndrome." Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

Synthetic Organic Chemicals (SOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
2,4-D (ppb)	N	<0.1	<0.1	70	70	09/2016	Runoff from herbicide used on row crops
2,4,5-TP (a.k.a. Silvex) (ppb)	N	<0.2	<0.2	50	50	09/2016	Residue of banned herbicide
Acrylamide				TT	0		Added to water during sewage / wastewater treatment
Alachlor (ppb)	N	<0.1	<0.1	2	0	08/2016	Runoff from herbicide used on row crops
Atrazine (ppb)	N	<0.05	<0.05	3	3	08/2016	Runoff from herbicide used on row crops
Benzo (a) pyrene (PAH) (ppt)	N	<20	<20	200	0	08/2016	Leaching from linings of water storage tanks and distribution lines
Carbofuran (ppb)	N	<0.5	<0.5	40	40	08/2016	Leaching of soil fumigant used on rice and alfalfa
Chlordane (ppb)	N	<0.1	<0.1	2	0	08/2016	Residue of banned termiticide
Dalapon (ppb)	N	<1	<1	200	200	09/2016	Runoff from herbicide used on rights of way
Di (2-ethylhexyl) adipate (ppb)	N	<0.6	<0.6	400	400	08/2016	Discharge from chemical factories
Di (2-ethylhexyl) phthalate (ppb)	N	<0.6	<0.6	6	0	08/2016	Discharge from rubber and chemical factories
Dibromochloropropane (ppt)	N	<10	<10	200	0	08/2016	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples,

							and orchards
Dinoseb (ppb)	N	<0.2	<0.2	7	7	09/2016	Runoff from herbicide used on soybeans and vegetables
Diquat (ppb)	N	<0.4	<0.4	20	20	08/2016	Runoff from herbicide use
Dioxin [a.k.a. 2,3,7,8-TCDD] (ppq)	N	<5	<5	30	0	09/2016	Emissions from waste incineration and other combustion; discharge from chemical factories
Endothall (ppb)	N	<5	<5	100	100	08/2016	Runoff from herbicide use
Endrin (ppb)	N	<0.01	<0.01	2	2	08/2016	Residue of banned insecticide
Epichlorohydrin				TT	0		Discharge from industrial chemical factories; an impurity of some water treatment chemicals
Ethylene dibromide (ppt)	N	<0.01	<0.01	50	0	08/2016	Discharge from petroleum refineries
Glyphosate (ppb)	N	6	6	700	700	08/2016	Runoff from herbicide use
Heptachlor (ppt)	N	<10	<10	400	0	08/2016	Residue of banned termiticide
Heptachlor epoxide (ppt)	N	<10	<10	200	0	08/2016	Breakdown of heptachlor
Hexachlorobenzene (ppb)	N	<0.05	<0.05	1	0	08/2016	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclo pentadiene (ppb)	N	<0.05	<0.05	50	50	08/2016	Discharge from chemical factories
Lindane (ppt)	N	<10	<10	200	200	08/2016	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor (ppb)	N	<0.05	<0.05	40	40	08/2016	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa,
Oxamyl (a.k.a. Vydate) (ppb)	N	<0.5	<0.5	200	200	08/2016	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
PCBs [Polychlorinated biphenyls] (ppt)	N	<10	<10	500	0	07/2004	Runoff from landfills; discharge of waste chemicals
Pentachlorophenol (ppb)	N	<0.04	<0.04	1	0	09/2016	Discharge from wood preserving factories
Picloram (ppb)	N	<1	<1	500	500	09/2016	Herbicide runoff
Simazine (ppb)	N	<0.05	<0.05	4	4	08/2016	Herbicide runoff
Toxaphene (ppb)	N	<0.5	<0.5	3	0	08/2016	Runoff/leaching from insecticide used on cotton and cattle
Volatile Organic Chemicals (VOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Benzene (ppb)	N	<0.5	<0.5	5	0	09/2010	Discharge from factories; leaching from gas storage tanks and landfills
Carbon tetrachloride (ppb)	N	<0.5	<0.5	5	0	09/2010	Discharge from chemical plants and other industrial activities
Chlorobenzene (ppb)	N	<0.5	<0.5	100	100	09/2010	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	N	<0.5	<0.5	600	600	09/2010	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	N	<0.5	<0.5	75	75	09/2010	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	N	<0.5	<0.5	5	0	09/2010	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	N	<0.5	<0.5	7	7	09/2010	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	N	<0.5	<0.5	70	70	09/2010	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	N	<0.5	<0.5	100	100	09/2010	Discharge from industrial chemical factories
Dichloromethane (ppb)	N	<0.5	<0.5	5	0	09/2010	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	N	<0.5	<0.5	5	0	09/2010	Discharge from industrial chemical factories
Ethylbenzene (ppb)	N	<0.5	<0.5	700	700	09/2010	Discharge from petroleum refineries
Styrene (ppb)	N	<0.5	<0.5	100	100	09/2010	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene (ppb)	N	<0.5	<0.5	5	0	09/2010	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene (ppb)	N	<0.5	<0.5	70	70	09/2010	Discharge from textile-

							finishing factories
1,1,1-Trichloroethane (ppb)	N	<0.5	<0.5	200	200	09/2010	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	N	<0.5	<0.5	5	3	09/2010	Discharge from industrial chemical factories
Trichloroethylene (ppb)	N	<0.5	<0.5	5	0	09/2010	Discharge from metal degreasing sites and other factories
Toluene (ppm)	N	<0.5	<0.5	1	1	09/2010	Discharge from petroleum factories
Vinyl Chloride (ppb)	N	<0.3	<0.3	2	0	09/2010	Leaching from PVC piping; discharge from chemical factories
Xylenes (ppm)	N	<0.001	<0.001	10	10	09/2010	Discharge from petroleum or chemical factories

Violation Summary (for MCL, MRDL, AL, TT, or Monitoring & Reporting Requirement)

Violation Type	Explanation, Health Effects	Time Period	Corrective Actions
SEE ATTACHED VIOLATIONS	NO HEALTH EFFECTS ASSOCIATED	2017	Reporting Process has Improved

<ul style="list-style-type: none"> •

<u>Arizona Department of Environmental Quality</u>		<u>Safe Drinking Water</u>	<u>Monitoring Assistance Program</u>
<u>County Map of Arizona</u>		<u>Water System Search</u>	<u>Help</u>
Water System Detail Information			
Water System ID #:	AZ0409029	Water System Classification:	C
Water System Name:	SNOWFLAKE TOWN OF	Primary Water Source:	GW
Principal County Served:	NAVAJO	System Activity / MAP Participant:	A - MAP
		Activity Date:	06-01-1977

Violation Detail			
Violation No:	2018-6138	Determination Date:	10-23-2017
Violation Type:	72	Violation Name:	CCR ADEQUACY/AVAILABILITY/CONTENT
Violation Category:	RPT	Status	V
Analyte code	7000	Analyte Name	CONSUMER CONFIDENCE RULE
Comp Prd Begin Date	10-01-2017	Comp Prd End Date	10-23-2017
Sampling Point			

Enforcement Actions					
EA Number	Action Type	PN Due/Proof PN Due PN Done/Proof PN Done	Action Name	Status	Date
2018-5102	SIA		ST VIOLATION/REMINDER NOTICE	T	10-23-2017
2018-5104	SOX		ST COMPLIANCE ACHIEVED	T	10-23-2017
2018-5103	TGN		GREEN VIOLATION CODE	T	10-23-2017

<u>Arizona Department of Environmental Quality</u>		<u>Safe Drinking Water</u>		<u>Monitoring Assistance Program</u>	
<u>County Map of Arizona</u>		<u>Water System Search</u>		<u>Help</u>	
Water System Detail Information					
Water System ID #:	AZ0409029	Water System Classification:	C		
Water System Name:	SNOWFLAKE TOWN OF	Primary Water Source:	GW		
Principal County Served:	NAVAJO	System Activity / MAP Participant:	A - MAP		
		Activity Date:	06-01-1977		

Violation Detail			
Violation No:	2017-6136	Determination Date:	04-28-2017
Violation Type:	27	Violation Name:	MONITORING, ROUTINE (DBP), MAJOR
Violation Category:	MON	Status	V
Analyte code	0999	Analyte Name	CHLORINE
Comp Prd Begin Date	01-01-2017	Comp Prd End Date	01-31-2017
Sampling Point	DISTRIBUTION SYSTEM		

Enforcement Actions					
EA Number	Action Type	PN Due/Proof PN Due PN Done/Proof PN Done	Action Name	Status	Date
2017-5100	SOX		ST COMPLIANCE ACHIEVED	T	04-14-2017
2017-5098	SIA		ST VIOLATION/REMINDER NOTICE	T	04-28-2017
2017-5099	TBF		TRIGGER BLUE FINAL	T	04-28-2017

Arizona Department of Environmental Quality		Safe Drinking Water		Monitoring Assistance Program	
County Map of Arizona		Water System Search		Help	
Water System Detail Information					
Water System ID #:	AZ0409029	Water System Classification:	C		
Water System Name:	SNOWFLAKE TOWN OF	Primary Water Source:	GW		
Principal County Served:	NAVAJO	System Activity / MAP Participant:	A - MAP		
		Activity Date:	06-01-1977		

Violation Detail			
Violation No:	2017-6134	Determination Date:	04-28-2017
Violation Type:	27	Violation Name:	MONITORING, ROUTINE (DBP), MAJOR
Violation Category:	MON	Status	V
Analyte code	0999	Analyte Name	CHLORINE
Comp Prd Begin Date	03-01-2017	Comp Prd End Date	03-31-2017
Sampling Point	DISTRIBUTION SYSTEM		

Enforcement Actions					
EA Number	Action Type	PN Due/Proof PN Due PN Done/Proof PN Done	Action Name	Status	Date
2017-5100	SOX		ST COMPLIANCE ACHIEVED	T	04-14-2017
2017-5094	SIA		ST VIOLATION/REMINDER NOTICE	T	04-28-2017
2017-5095	TBF		TRIGGER BLUE FINAL	T	04-28-2017

Arizona Department of Environmental Quality		Safe Drinking Water		Monitoring Assistance Program	
County Map of Arizona		Water System Search		Help	
Water System Detail Information					
Water System ID #:	AZ0409029	Water System Classification:	C		
Water System Name:	SNOWFLAKE TOWN OF	Primary Water Source:	GW		
Principal County Served:	NAVAJO	System Activity / MAP Participant:	A - MAP		
		Activity Date:	06-01-1977		

Violation Detail			
Violation No:	2017-6135	Determination Date:	04-28-2017
Violation Type:	27	Violation Name:	MONITORING, ROUTINE (DBP), MAJOR
Violation Category:	MON	Status	V
Analyte code	0999	Analyte Name	CHLORINE
Comp Prd Begin Date	02-01-2017	Comp Prd End Date	02-28-2017
Sampling Point	DISTRIBUTION SYSTEM		

Enforcement Actions					
EA Number	Action Type	PN Due/Proof PN Due PN Done/Proof PN Done	Action Name	Status	Date
2017-5100	SOX		ST COMPLIANCE ACHIEVED	T	04-14-2017
2017-5096	SIA		ST VIOLATION/REMINDER NOTICE	T	04-28-2017
2017-5097	TBF		TRIGGER BLUE FINAL	T	04-28-2017

Arizona Department of Environmental Quality		Safe Drinking Water		Monitoring Assistance Program	
County Map of Arizona		Water System Search		Help	
Water System Detail Information					
Water System ID #:	AZ0409029	Water System Classification:	C		
Water System Name:	SNOWFLAKE TOWN OF	Primary Water Source:	GW		
Principal County Served:	NAVAJO	System Activity / MAP Participant:	A - MAP		
		Activity Date:	06-01-1977		

Violation Detail			
Violation No:	2017-6126	Determination Date:	11-03-2016
Violation Type:	27	Violation Name:	MONITORING, ROUTINE (DBP), MAJOR
Violation Category:	MON	Status	V
Analyte code	2950	Analyte Name	TTHM
Comp Prd Begin Date	01-01-2016	Comp Prd End Date	12-31-2016
Sampling Point	DISTRIBUTION SYSTEM		

Enforcement Actions					
EA Number	Action Type	PN Due/Proof PN Due PN Done/Proof PN Done	Action Name	Status	Date
2017-5089	SIA		ST VIOLATION/REMINDER NOTICE	T	11-03-2016
2017-5090	TGN		GREEN VIOLATION CODE	T	11-03-2016
2017-5101	SOX		ST COMPLIANCE ACHIEVED	T	08-08-2017

<u>Arizona Department of Environmental Quality</u>		<u>Safe Drinking Water</u>		<u>Monitoring Assistance Program</u>	
<u>County Map of Arizona</u>		<u>Water System Search</u>		<u>Help</u>	
Water System Detail Information					
Water System ID #:	AZ0409029	Water System Classification:	C		
Water System Name:	SNOWFLAKE TOWN OF	Primary Water Source:	GW		
Principal County Served:	NAVAJO	System Activity / MAP Participant:	A - MAP		
		Activity Date:	06-01-1977		

Violation Detail			
Violation No:	2017-6127	Determination Date:	11-03-2016
Violation Type:	27	Violation Name:	MONITORING, ROUTINE (DBP), MAJOR
Violation Category:	MON	Status	V
Analyte code	2456	Analyte Name	TOTAL HALOACETIC ACIDS (HAA5)
Comp Prd Begin Date	01-01-2016	Comp Prd End Date	12-31-2016
Sampling Point	DISTRIBUTION SYSTEM		

Enforcement Actions					
EA Number	Action Type	PN Due/Proof PN Due PN Done/Proof PN Done	Action Name	Status	Date
2017-5089	SIA		ST VIOLATION/REMINDER NOTICE	T	11-03-2016
2017-5090	TGN		GREEN VIOLATION CODE	T	11-03-2016
2017-5101	SOX		ST COMPLIANCE ACHIEVED	T	08-08-